Identification and Solutions to Common Pretreatment Violations on Army Installations

Jennifer L. Dauphinais and Laura Lokey-Flippo

U.S. Army Center for Health Promotion and Preventive Medicine

Surface Water and Wastewater Program

March 2006

Pretreatment Basics

Goal of pretreatment:

To protect, preserve and improve surface water quality.


How?

Limit pollution from nondomestic dischargers to WWTPs.

Nondomestic discharges include wastewater from commercial or industrial sources



Dining Halls



Laboratories



Maintenance Shops



Health Care Facilities

Currently, it is not required for FOTWs to have a pretreatment program

More stringent discharge requirements

+

Continued privatization of GOGO utilities

Voluntary implementation of pretreatment programs




A variety of discharge limits may be implemented depending on installation activities and size.

Parameters	Mechanical Testing and Range Activity Discharge Limits (mg/L)	Chemical and Biological Activity Discharge Limits (mg/L)
BOD ₅	908.0	566.0
TSS	1320.0	595.0
Ammonia – N	40.0	40.0
Phosphorus, total	31.3	45.0
TPH	100.0	100.0
TTO	2.13	2.13
Cadmium, total	0.10	0.10
Chromium, total	0.70	0.50
Lead, total	0.30	0.10
Mercury, total	0.002	0.002
Silver, total	0.10	0.10
Zinc, total	5.50	1.00
Cyanide, total	1.30	3.60

During pretreatment compliance evaluations, six recurring findings have emerged.

- 1. Ammonia
- 2. Mercury
- 3. Low Flow
- 4. BOD₅ and TSS
- 5. Silver
- 6. Paperwork/Notification



Ammonia in excess of discharge requirements was found at many different facilities

- Facilities were mainly domestic dischargers
- Or not expected to contain ammonia at all
- Often 2-3 times the discharge requirement (40 mg/L)

Source of ammonia likely from disinfectant cleaners used to sanitize restrooms.

Most government facilities have fazed out ammonia cleaners for environmental and safety reasons.

Alternative cleaners still contain ammonium salts

 Orange (citrus) –based clear alternative to ammonia-cont



Mercury violations were common at health care facilities.

- Levels found as high as 500x the discharge limit (0.002mg/L)
- Mercury found predominantly in wastewater solids



There are still many sources of mercury in health care facilities despite minimization programs.


- Cleaners, reagents, pigments and stains
- X-ray processing fixer
- Historical spills/discharges
- Dental amalgam



Mercury minimization options for health care facilities.

- Remove mercury-containing thermometers and reagents
- Consider investigating sink traps for historical contaminations
- Collecting amalgam solids too small for sink and chair traps
- Mercury separation devices can be the option

Example amalgam separation diagram



Low flow waste streams continually exceeded multiple discharge limits

■ Flow < 2,500 gpd

 Concentrations often exceeded limits although discharger impact on the WWTP is negligible

For small industrial dischargers conc. based


limits:

- Can be burdensome
- May hinder water conservation practices

Loading-based discharge limits may be more appropriate for low flow dischargers

 EPA allows for industrial user limits to be determined on a case by case basis

A combination of concentration-based and loading-based limits is allowable for a single



BOD₅ and TSS concentrations routinely exceeded limits at military dining facilities

- Contained food wastes from garbage disposals
- Increased BOD loading can be beneficial to organically under loaded WWTPs

 Consideration should be given to relaxing these limits at dining facilities that contribute to organically under loaded WWTPs

Silver concentrations from photo processors exceeded discharge limits

Photo-finishing effluents often contain Cd and Ag (in the form of CdBr₂ and AgNO₃)

 Ion exchange silver recovery systems should be tested for effectiveness regularly


 Consider going to digital photo processing systems



Discharge waivers often not renewed or present at the discharge locations

- Continued personnel education on:
 - Proper handling procedures
 - Potential effects of illicit or inadvertent discharges
- Implementing harsher consequences for pretreatment violations may also be a viable deterrent

Notifying dischargers of violations



In conclusion

- Six recurring pretreatment findings (and solutions):
 - Ammonia
 - Mercury
 - Low Flow
 - BOD₅ and TSS
 - Silver
 - Paperwork

• Questions?

